





Solar Heating in Industrial Processes (SHIP) Project

The project "**Utilizing Solar Energy for Industrial Process Heat in Egyptian Industry**" is financed by the GEF and implemented by UNIDO in partnership with the Egypt National Cleaner Production Centre ENCPC. The objective of the project is to develop the market environment for the diffusion and local manufacturing of solar energy systems for industrial process heat. The project results will increase the knowledge and strengthen the awareness among the major stakeholders on the penetration potential of solar technologies in the food, chemical and textiles sectors in the region. The project focuses on improving the energy efficiency of the industrial process heating systems and the introduction of solar thermal technologies mainly in industrial companies that have low and medium temperature heat demand in three industrial sectors, namely the food, chemical and textiles sectors.

Phatrade - Pharaonic Essential Oils Co. – Obour City Plant Case Study



Production Processes Flow Diagram



Phatrade - Pharaonic Essential Oils is part of the food sector for essential Oils products in Egypt. Phatrade has been established in 1975 in the Spices and herbs field and started essential oils and concretes and absolutes products in 1987. The production of Phatrade company is assigned for the local and export markets. Phatrade – Obour City factory is one of the two operating Phatrade factories.

Phatrade – Obour City factory's processes flow diagram exhibits the main processes performed on the raw material to produce Cumin, Neroli, Parsley, Thyme, Chamomile and Anise oils products. General analysis on the thermal energy consumption shows that the average specific **diesel** consumption is about 152.6 kWh_{th}/Kg which is much higher than the average worldwide specific energy consumption benchmark.

Thermal energy system is supplied through a steam boiler of 1 Ton/hr capacity and supply steam at 6.5 bar. The analysis shows that it is operating at part load most of the time and has about 0.43 ton/hr average steam production. Applying the suggested optimization measures will eliminated unnecessary losses and the factory can operate at much lower cost.

- Optimization Opportunities -



Thermal Insulation



Waste Heat Utilization



Boiler Optimization

Solar Water Heating

Thermal Insulation	Optimizing Boiler's Blowdown Flow Rate	Improvement in Burner Efficiency with an
Insulation of pipes and fittings is a general	Using a fixed rate of blowdown does not take	Oxygen Analyzer
principle that should be applied in all steam	into account changes in makeup and feed	The excess air is not automatically controlled
consuming processes in the factories. The	water conditions, variations in steam	in the boiler, thus the air to fuel ratio is not
proposed solution is to fix the insulation at	demand or the actual concentration of	optimal and leads to an increased fuel bill.
multiple parts of the steam system. The	dissolved solids in the boiler's water. The	The proposed solution is to install an online
collective saving from proper insulation is	proposed solution is to install an automatic	combustion gas analyzer and manual
usually enormous. Insulation will help to	control system optimizing blowdown rates.	adjustment of the air damper to improve
reduce energy consumption, CO ₂ emissions,	This will reduce energy consumption,	burner efficiency. This requires low capital
and operation costs. safety will be enhanced	treatment, CO2 emissions, and operation	cost and results in huge CO2 emissions and
after reducing surface temperature from 170	costs.	operation costs reduction.
°C to 45 °C.		
Capex: 21 USD/meter	Capex: 7,000 USD	Capex: 1,750 USD
Energy Savings: 1,800 kWh/year/meter	Energy Savings: 57,760 kWh/year	Energy Savings: 9,470 kWh/year
Payback: 0.26 years	Payback: 2.8 years	Payback: 4.7 years
CO ₂ Reduction: 0.48 tCO ₂ /year/meter	CO ₂ Reduction: 15 5 tCO ₂ /year	CO ₂ Reduction: 2.6 tCO ₂ /year

Integration of Solar Thermal Heating System

Solar heating technologies collect thermal energy from the sun and this heat can be used for heating purposes. Solar collectors are selected based on the range of the operating temperature range and the type of the industrial sector. Heat in the lower temperature range (<100 °C) can easily be provided with systems commercially available, such as flat plate collectors (FPC) and evacuated tube collectors (ETC). The **scenario envisioned** for the factory is to **preheat boiler feed water** by recovering energy from boiler's exhaust gases and blowdown water followed by heating using solar system which will decrease the energy consumed by the boiler. The system will be **installed on the roof** occupying **110** m² of area. The system is designed to **heat 5.2** m³/day to **95** °C. The system cost is around USD **54,950** and the **annual savings** will be **USD 5,945**. Other parameters are shown below.



Lessons Learnt

- Thermal insulation is a quick win. It saves energy with very low upfront costs and have high impact and low payback.
- Boiler optimization requires low efforts but have high impact on CO₂ emissions reduction.
- Waste energy utilization is not a common measure, however highest energy saving can be achieved by this measure.
- Solar thermal integration combines renewable energy resources utilization and energy savings measures.

The total proposed solutions summary:

- Thermal Energy Savings: up to 413,340 kWh/year, representing about 36.3% savings of the total thermal energy consumption (where 13.3% is due to the integration of SWH systems),
- Financial Savings: 44,690 USD/year,
- Capital Cost: ~69,275 USD,
- Overall Payback Period: 1.55 years,
- CO₂ Emissions Reduction: 193 tCO₂eq/year.





For more information:

UNIDO Project Management Unit in Egypt, Email: <u>info@shipprojectegypt.org</u> Phone: +20 102 895 1112 www.SHIPprojectEgypt.org

UNIDO Headquarters:

Mark Draek, Email: <u>m.draeck@unido.org</u> Phone: +43 (1) 26026 4356